

END OF LIFE (EOL) EQUIPMENT LIST

<u>BUILD</u>	<u>EQUIP</u>	<u>NOMENCLATURE</u>	<u>FLOOR</u>	<u>ROOM</u>	<u>MFR</u>	<u>MODEL</u>	<u>SERIAL NO</u>	<u>INSTALLE</u>
CHL	HL093	HVAC UNIT-2. ELEC HEAT. CEILING MOUNT	GR	1S3	LENNOX	CBS18-51-3P	5189E68128	
CUB	CU009	AIR COMPRESSOR 1A. CONTROL AIR,7.5 HP 17.1CFM @100PSI	GR	COLUMN B9	CORKEN	A490K7FB	TB24366	
CUB	CU046	AIR COMPRESSOR 1B. CONTROL AIR., 7.5HP 17.1 CFM @100PSI	GR	COLUMN C9	CORKEN	A490K7FB	VM28413	
F55WS3	F200	GAS UNIT HEATER UH-1. 350,00BTU PROPANE	OFFICE		WILLIAMS F	435FX-R	G02150121	
FCCF	0000001721	HEAT RECOVERY WHEEL HXW-2 60"DIA 1/3HP 120V 1PH VARIABI	3FL	366	CARGOCAIRE	SENEX SA90		
FCCF	0000001732	HEAT RECOVERY WHEEL HXW-1 48"D1A 1/4HP 120V 1PH	GR	118	CARGOCAIRE	SENEX-SA50		
FCCF	FCCF022	HEAT PUMP VHP-10. 800CFM,3.1GPM 208V PERM LUB	SECOND	251	TRANE	WPRD-02611F20E	W96C07354	8/30/96
FCCF	FCCF067	EXH FAN. DIRECT DRIVE.	GR	101	BROAN	HA3E023N#	14507J1	
FRPB	AC853UH04	UNIT HEATER, LP GAS, UH-4, 30K BTU			STERLING	QVF-20X3 PACK	08862242	
FRPB	AC853UH05	UNIT HEATER, LP GAS, UH-5, 30K BTU			STERLING	QVF-20X3 PACK	SNA	
FRPB	AC853UH06	UNIT HEATER, LP GAS, UH-6, 30K BTU			STERLING	QVF-20X3 PACK	SNA	
KRS	UT211	HVAC ACU-7,9KW HEAT	OUT WALL	EAST	MARVAIR	AVP36ACD09C-1C	CH40463	2/4/98
KTEV	NL928	MUNTERS DEHUMIDIFIER. DESICCANT TYPE.	OUT	NORTH	CARGOCAIRE	HC4500EA	820	3/28/97
LINAC	L138	AIR COMPRESSOR ACO-1A. N. OF MACH SHOP, SOUTH UNIT	B1C	LIU000	CORKEN	A490K7FBA 7.5H	RC22408	
LINAC	L139	AIR COMPRESSOR ACO-1B. N. OF MACH SHOP, NORTH UNIT. BE	B1C	LIU000	CORKEN	A490M7FBA 7.5H	AY36537	
LINAC	L423	AC UNIT AC-8	NLAU	AT NO WALL	HEAT EXCHA	KOLDWAVE 5K19	N3-143719	
LINAC	L424	AC UNIT AC-9	NLAU	AT NO WALL	HEAT EXCHA	KOLDWAVE 5K19	N3-144300	
MS2	ML022	AIR COMPRESSOR ACO-1,EAST UNIT	MR		CORKEN	A490K7FB	24786-TYPICAL	
MS2	ML023	AIR COMPRESSOR ACO-2,WEST UNIT	MR		CORKEN	A490K7FB	24786-TYPICAL	
NS1	NL004	COMPRESSOR, AIR, ACO-1	INT	PUMP RM	CORKEN	CP490896	UNIT-VF27483	
NS1	NL005	COMPRESSOR, AIR, ACO-2	INT	PUMP RM	CORKEN	CP490896	UNITVF27483	
P01	PL009.1	HEAT & VENT UNIT HV-2	OUT	S ENTRANCE	TRANE	GRCA30GFHBN;	A96H42046	1/1/97
PHIL	PL268	FAN COIL UNIT FCU-7. FILTER 1@16X20X2. OUTSIDE CT4.	GRC	CEILING	MCQUAY	SCD 081A	4GC42425-O1	
PHIL	PL270	FAN COIL UNIT FCU-9,RM IN FRONT OF CT2.	GR	WORKSHOP	MCQUAY	SCD 081A	4GC42426-TYP.	
PHIL	PL271	FAN COIL UNIT FCU-10	GR	CLEAN	MCQUAY	SCD 081A	4GC42426-TYP.	
PTPL	PL128	UNIT HEATER UH-8. 30KW 460V 3PH	GR	PUMP RM	CHROMALOX	LUH-30-03-AR00T	LUH-30-03-ARO-	
PW5	PL635	ELEC UNIT HEATER. 50' PIT N/E	50' PIT	N/E	CHROMALOX			
VL03	VL039	GAS UNIT HTR-10. EAST ANNEX NORTH DOOR	EAST ANNE	ADDITION	STERLING	CF125	C793D114	
VL03	VL385	AC CONDENSING UNIT AC-5. FOR NORTH SMALL CLEAN RM. 460	OUT	NORTH	CARRIER	38CKC060620	2400E03362	9/29/00
VL04	VL377	COMPRESSED AIR DRYER, REFRIG. 115V	GR		PNEUMATECH	AD-125	9910-T132393-ST	
VL06	VL074	GAS UNIT HTR-4 LAB 6 S/W	GR	HIGH BAY	MODINE	P135A		
VL6A	VL129	AIR HANDLER, ACU-1 600MBH 7-1/2HP. CHW	OUT WEST	FENCE AREA	TRANE	GRAA60GFHBN;	A96E36663	10/1/96
WHL	CL106	CHILLER CH-1. 90 TON. STANDBY CHILLED WATER FOR COMPUT	B1C		CARRIER	30HR090600	G786242	
TOTAL		33						